

Montclair Board of Education
Drinking Fountain Survey 2016 - 2017 School Year
District Wide

School	Location	Type	Test by Township of Mtc - Date	Test by Township of Mtc - Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Comments
Hillside School	Room 24A	Drinking Fountain						not working - out of service									Unit shut off
Montclair Community Pre-K	2N Rm 7	Drinking Foutain					8/2/2016	None detected									
Montclair Community Pre-K	Kitchen	Sink	3/11/2016	<2 ugl													
Montclair Community Pre-K	Nurse Office	Sink							11/15/2016	BDL							
Montclair Community Pre-K	Rm next to Gym	Drinking Foutain															Unit shut off
Montclair Community Pre-K	Room 1	Drinking Foutain					8/2/2016	None detected									
Montclair Community Pre-K	Room 10	Drinking Foutain					8/2/2016	None detected									
Montclair Community Pre-K	Room 11	Drinking Foutain					8/2/2016	None detected									
Montclair Community Pre-K	Room 12	Drinking Foutain					8/2/2016	None detected									
Montclair Community Pre-K	Room 13	Drinking Foutain					8/2/2016	None detected									
Montclair Community Pre-K	Room 14	Drinking Foutain					8/2/2016	None detected									
Montclair Community Pre-K	Room 15	Drinking Foutain					8/2/2016	None detected									
Montclair Community Pre-K	Room 16	Drinking Foutain					8/2/2016	None detected									
Montclair Community Pre-K	Room 2	Drinking Foutain	3/11/2016	<2 ug/L													
Montclair Community Pre-K	Room 3	Drinking Foutain	3/11/2016	<2 ug/L													
Montclair Community Pre-K	Room 4	Drinking Foutain					8/2/2016	None detected									
Montclair Community Pre-K	Room 5	Drinking Foutain					8/2/2016	None detected									
Montclair Community Pre-K	Room 6	Drinking Foutain					8/2/2016	None detected									
Montclair High School	1st Floor boys Room	Drinking Fountain					8/3/2016	None detected	10/6/2016	135 ppb			12/28/16	43.9 ppb			Unit Shut Off
Montclair High School	1st Floor by room 111	Drinking Fountain					8/3/2016	None detected									
Montclair High School	1st Floor Girls Room	Drinking Fountain					8/3/2016	None detected									
Montclair High School	2nd floor boys room	Drinking Fountain					8/3/2016	2 ppb	10/6/2016	<3 ppb							
Montclair High School	2nd floor Girls Room	Drinking Fountain					8/3/2016	2 ppb	10/6/2016	3.34 ppb				broken			Unit Shut Off
Montclair High School	2nd floor hallway by Room 216	Drinking Fountain					8/3/2016	None Detected									
Montclair High School	2nd Floor hallway by Room 219	Drinking Fountain					8/3/2016	None Detected									
Montclair High School	3rd floor Hallway boys Room	Drinking Fountain					8/3/2016	4 ppb	10/6/2016	<3 ppb							
Montclair High School	3rd floor Hallway girls room	Drinking Fountain					8/3/2016	6 ppb									Unit Shut Off
Montclair High School	Auditorium - men's bathroom	Drinking Fountain					8/3/2016	No info given	10/6/2016	249 ppb			12/28/16	83.1 ppb			Unit Shut Off
Montclair High School	Auditorium - north gallery	Drinking Fountain					8/3/2016	2 ppb	10/6/2016	31.9 ppb			12/28/16	BDL			
Montclair High School	Auditorium Balcony	Drinking Fountain							10/6/2016	212 ppb			12/28/16	88.5 ppb			Unit Shut Off
Montclair High School	Autoshop	Drinking Fountain							10/6/2016	<3 ppb							
Montclair High School	Basement Room 16	Drinking Fountain					8/3/2016	380 ppb	10/6/2016	<3 ppb							
Montclair High School	Boys locker room	Drinking Fountain							10/6/2016	<3 ppb							
Montclair High School	CST	Drinking Fountain					8/3/2016	None detected									
Montclair High School	Driver Ed/Small Café	Drinking Fountain					8/3/2016	3 ppb	10/6/2016	5.73 ppb			12/28/16	5.58 ppb			Unit Shut Off
Montclair High School	Girls bath basement	Drinking Fountain					8/3/2016	None detected									
Montclair High School	Gym main lobby boys bath	Drinking Fountain					8/3/2016	None detected									
Montclair High School	Gym main lobby girls bath	Drinking Fountain					8/3/2016	None detected									
Montclair High School	Gym office & main gym	Drinking Fountain					8/3/2016	None detected									
Montclair High School	Home economics - sink #2	Sink											4/20/17	BDL			
Montclair High School	Home economics - sink #3	Sink											4/20/17	BDL			
Montclair High School	Home economics - sink on west side of room	Sink											4/20/17	BDL			
Montclair High School	Home economics - sink #4	Sink											4/20/17	BDL			
Montclair High School	Home economics - stainless steel sink faucet	Sink											4/20/17	BDL			
Montclair High School	Ice machine back of kitchen by outside door	Ice Machine											5/16/17	BDL			

Montclair Board of Education
 Drinking Fountain Survey 2016 - 2017 School Year
 District Wide

School	Location	Type	Test by Township of Mtc - Date	Test by Township of Mtc - Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Comments
Montclair High School	Kitchen	Sink	3/11/2016	2.98 ug/L	3/28/2016	<3 ppb											
Montclair High School	Large Gym	Drinking Fountain	3/11/2016	<2 ug/L													
Montclair High School	Main Cafeteria by custodian closet	Drinking Fountain	3/11/2016	<2 ug/L													
Montclair High School	Nurse Office - Bed Area	Sink									11/15/16	299 ppb	12/28/16	BDL			
Montclair High School	Nurse Office - Main Area	Sink									11/15/16	BDL					
Montclair High School	Room 14	Drinking Fountain					8/3/2016	None detected									
Montclair High School	Room 17	Drinking Fountain					8/3/2016	None detected									
Montclair High School	Small Gym	Drinking Fountain					8/3/2016	None detected									
Montclair High School	Trainer's room ice machine	Ice Machine											4/20/17	7.30 ppb	8/2/2017	ND	
Montclair High School	woodshop	Drinking Fountain							10/6/2016	<3 ppb							
Nishuane School	1st floor near Rm 109	Drinking Fountain	3/11/2016	<2 ug/L													
Nishuane School	1st floor near Teach Lounge	Drinking Fountain			8/4/2016	None detected											
Nishuane School	2nd floor near rm 203	Drinking Fountain			8/4/2016	None detected											
Nishuane School	2nd floor near rm 211	Drinking Fountain			8/4/2016	26 ppb	10/11/2016	22.8 ppb									Unit shut down
Nishuane School	2nd floor near rm 213	Drinking Fountain			8/4/2016	None detected											
Nishuane School	Basement Hall by Custodial room	Drinking Fountain			8/4/2016	None detected											
Nishuane School	Hall by Room B-11	Drinking Fountain			8/4/2016	None detected											
Nishuane School	Hall by Room B-13	Drinking Fountain	3/11/2016	<2 ug/L													
Nishuane School	Kitchen	Sink	3/11/2016	<2 ug/L													
Nishuane School	Nurse Office	Sink							11/15/2016	BDL							
Nishuane School	outside near swing area	Drinking Fountain			8/4/2016	None detected											
Nishuane School	Teachers Room	Sink							5/16/2017	BDL							
Northeast School	by Elevator Ground Floor	Drinking Fountain					10/14/2016	<3 ppb									
Northeast School	by Rm 28	Drinking Fountain			8/2/2016	1 ppb	10/14/2016	<3 ppb									
Northeast School	Cooler by Kitchen	Cooler	3/11/2016	<2 ug/L													
Northeast School	Hall by Room 13 & 14	Drinking Fountain			8/2/2016	None detected	10/14/2016	<3 ppb			12/26/16	BDL					
Northeast School	Hall by Room 22	Drinking Fountain	3/11/2016	<2 ug/L			10/14/2016	<3 ppb									
Northeast School	Hall by room 32	Drinking Fountain			8/2/2016	None detected											
Northeast School	Kitchen	Sink	3/11/2016	<2 ug/L													
Northeast School	Nurse Office	Sink							11/16/2016	BDL							
Northeast School	Rm 26	Drinking Fountain			8/2/2016	2 ppb	10/14/2016	<3 ppb									
Northeast School	Rm 27	Drinking Fountain			8/2/2016	2 ppb	10/14/2016	<3 ppb									
Northeast School	Rm 28	Drinking Fountain			8/2/2016	None detected											
Northeast School	Rm 30 on sink	Drinking Fountain			8/2/2016	None detected											
Northeast School	Rm 32 on sink	Drinking Fountain			8/2/2016	None detected											
Northeast School	Rm 33 on sink	Drinking Fountain			8/2/2016	None detected	10/14/2016	<3 ppb									
Northeast School	Room 13	Drinking Fountain			8/2/2016	8 ppb	not working				not working						Unit shut down
Northeast School	Room 14	Drinking Fountain			8/2/2016	12 ppb	not working				not working						Unit shut down
Northeast School	Room 25	Drinking Fountain			8/2/2016	1 ppb	10/14/2016	3.89 ppb			12/28/16	BDL					
Northeast School	Room 34	Drinking Fountain			8/2/2016	None detected											
Northeast School	Teachers Room	Sink									5/17/17	BDL					
Renaissance School at the Rand Building	1st Floor by Room 111	Drinking Fountain	3/11/2016	<2 ug/L													
Renaissance School at the Rand Building	1st Floor by Room 120A	Drinking Fountain	3/11/2016	<2 ug/L													
Renaissance School at the Rand Building	2nd floor by Room 206	Drinking Fountain															
Renaissance School at the Rand Building	2nd Floor by Room 217	Drinking Fountain			8/8/2016	None Detected											
Renaissance School at the Rand Building	7 classrooms	Drinking Fountain															Units are shut off
Renaissance School at the Rand Building	Kitchen	Sink	3/11/2016	<2 ug/L													
Renaissance School at the Rand Building	Nurse Office	Sink							11/16/2016	BDL							

